

M7- M12 Integration Project

Environment Protection Licence – Environmental Monitoring Data Report

December 2025



Document Control

Date	08 January 2026
Document No.	M7M12UDC-JHGRP-M7A-EN-RPT-000044
Title	Environment Protection Licence – Environmental Monitoring Data Report December 2025

Document History and Status

Rev	Rev Date	Description	Author	Checked	Reviewed	Approved
01	06/01/2026	For publication	K. Hernandez	D. Windnagel	D. Windnagel	For publication

Contents

1	Project summary	2
2	Environmental Protection Licence and Reporting Requirements	4
3	Noise and vibration monitoring	5
3.1	Noise monitoring	5
3.2	Vibration monitoring	12
4	Discharge Water Quality Monitoring	16

Figures

Figure 1-1 M7-M12 Integration Project	3
--	----------

Tables

Table 3-1 Noise monitoring data	6
Table 3-2 Vibration monitoring data	13
Table 4-1 Sediment basin discharge monitoring data for October 2025	17


1 Project summary

The M7 Motorway (Modification 6 Widening; SSI-663-Mod-6) (M7 Widening) and the M12 East package of the M12 Motorway project (SSI 9364) will be delivered together under what is referred to as the M7-M12 Integration project (the Project) (refer to Figure 1-1) by John Holland.

The M12 Motorway extends between the M7 Motorway at Cecil Hills and The Northern Road at Luddenham, over a distance of about 16 km. It will be delivered in multiple packages including the M12 West package, M12 Central package and M12 East package (this package is part of the M7-M12 Integration project). The M12 East package involves two components of work:

- Connecting Elizabeth Drive to the M12 Motorway and the upgrade of approximately two kilometres of Elizabeth Drive from east of Duff Road to 300 metres east of the M7 Motorway
- Providing a grade separated motorway to motorway connection between the M7 Motorway and M12 Motorway.

The M7 Widening project will enable the construction and operation of an additional lane in both directions within the existing median of the Westlink M7 for approximately 26 kilometres (km). Works will occur from about 140 metres (m) south of the Kurrajong Road overhead bridge at Prestons (southern end) to the Richmond Road interchange at Oakhurst/Glendenning (northern end), excluding widening through the Westlink M7/M4 Motorway (Light Horse) Interchange.



M7-M12 INTEGRATION PROJECT LOCATION OVERVIEW



AECOM

Legend

- M7 Widening
- M7-M12 Interchange
- Elizabeth Drive Connection
- M12 Motorway
- Existing motorway
- Interchange
- LGA boundary
- Suburb boundary

Copyright: Copyright information regarding the use of the text is provided in the page footer. For further information, see Creative Commons, Attribution-NonCommercial-ShareAlike 3.0. (http://creativecommons.org/licenses/by-nc-sa/3.0/), De Gruyter Database and/or Digital Topographic Database.

The terms of Creative Commons Attribution 4.0 International License are available at <https://creativecommons.org/licenses/by/4.0/legalcode> (Legal code | Copyright license).

Neither Abu Dhabi Airports Pty Ltd nor the Department of Customer Services makes any representations or warranties of any kind, about the accuracy, reliability, currency or completeness of any data or information contained in the contract (in accordance with section 6 of the Contract) or in any document or information provided by the Client for the use of the Client, based on the Client's description of the requirements having regard to the circumstances and conditions of the contract (in accordance with clause 2).

Downloaded from www.jstor.org at 00:00 09 January 2017

Figure 1-1 M7-M12 Integration Project

2 Environmental Protection Licence and Reporting Requirements

John Holland Pty Ltd obtained the Environment Protection Licence (EPL No. 21829) from the NSW Environment Protection Authority for the project. The licence is for road construction as defined under Schedule 1 of the *Protection of the Environment Operations Act 1997* (POEO Act).

The licence describes monitoring and reporting requirements for the Works. The following report details environmental monitoring undertaken during the December 2025 monitoring period conducted in accordance with the EPL.

The EPL can be found by following the link below to the EPA's website: epa.nsw.gov.au.

3 Noise and vibration monitoring

3.1 Noise monitoring

Noise monitoring was undertaken during the reporting period in accordance with the requirements of the M7M12 Construction Noise and Vibration Monitoring Program (M712UDC-JHGRP-M7A-EN-PLN-000074).

All works were deemed compliant as they complied with applicable criteria, monitoring was predominantly dominated by background noise sources such as local traffic and are detailed in Table 3-1.

Table 3-1 Noise monitoring data

Location Description	Monitoring date	Monitoring period	NCA	Attended or Continuous	Parameter	Measured value dB(A)	Goals and targets dB(A)	Project OOHW Compliance	Comments/Field Observations
24 Haleluka Crescent, Plumpton	02/12/2025	Night	NCA_28	Attended	LAeq (15 min)	49.6	68	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
15 Gimi Grove, Plumpton	02/12/2025	Night	NCA_28	Attended	LAeq (15 min)	48.5	67	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
137 Ash Road, Prestons	02/12/2025	Night	NCA_06	Attended	LAeq (15 min)	55.4	65	JH Works Compliant	Dominant noise source was traffic from local roads. Works were inaudible. JHG works compliant.
8A Skipton Lane, Prestons	03/12/2025	Night	NCA_06	Attended	LAeq (15 min)	57.3	65	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
37 Rossini Drive, Hinchinbrook	03/12/2025	Night	NCA_07	Attended	LAeq (15 min)	48	52	JH Works Compliant	Dominant noise source was traffic from local roads. Works were inaudible. JHG works compliant.
31 Isabel Street, Cecil Hills	03/12/2025	Night	NCA_16b	Attended	LAeq (15 min)	43.3	65	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
3A Gregory Street, Glendenning	03/12/2025	Night	NCA_31	Attended	LAeq (15 min)	49.3	71	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
64 Woodley Cres, Glendenning	03/12/2025	Night	NCA_28	Attended	LAeq (15 min)	43	62	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
11 Gilpin Place, Plumpton	03/12/2025	Night	NCA_28	Attended	LAeq (15 min)	48.6	67	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
37 Rossini Drive, Hinchinbrook	03/12/2025	Night	NCA_07	Attended	LAeq (15 min)	46.2	52	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
30 Angou Circuit, Cecil Hills	04/12/2025	Night	NCA_16	Attended	LAeq (15 min)	43.2	41	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
5 Nimbin Avenue, Hoxton Park	04/12/2025	Night	NCA_08	Attended	LAeq (15 min)	47.9	51	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
233-243 Wallgrove Road, Cecil Park	04/12/2025	Night	NCA_17	Attended	LAeq (15 min)	64.7	65	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.

Location Description	Monitoring date	Monitoring period	NCA	Attended or Continuous	Parameter	Measured value dB(A)	Goals and targets dB(A)	Project OOHW Compliance	Comments/Field Observations
64 Woodley Cres, Glendenning	04/12/2025	Night	NCA_28	Attended	LAeq (15 min)	47.1	63	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
27 Myra Street, Plumpton	04/12/2025	Night	NCA_31	Attended	LAeq (15 min)	45.2	76	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
15 Lambert Avenue, Plumpton	05/12/2025	Night	NCA_31	Attended	LAeq (15 min)	47.7	70	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
33 Isabel Street, Cecil Hills	05/12/2025	Night	NCA_16b	Attended	LAeq (15 min)	50.8	79	JH Works Compliant	Dominant noise source was project works. Works were compliant with the PNL. JHG works compliant.
3 Meredith Way, Cecil Hills	05/12/2025	Night	NCA_16b	Attended	LAeq (15 min)	45.7	69	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
2055- 2059 Elizabeth Drive, Cecil Park	05/12/2025	Night	NCA_35	Attended	LAeq (15 min)	57.6	51	JH Works Compliant	Dominant noise source was traffic from local roads. Works were inaudible. JHG works compliant.
18 Cecil Road, Cecil Park	06/12/2025	Night	NCA_35	Attended	LAeq (15 min)	72.1	65	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
37-73 Wallgrove Road, Cecil Park	06/12/2025	Night	NCA_17	Attended	LAeq (15 min)	52.9	67	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
37-73 Wallgrove Road, Cecil Park	06/12/2025	Night	NCA_17	Attended	LAeq (15 min)	53	67	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
2055- 2059 Elizabeth Drive, Cecil Park	06/12/2025	Night	NCA_35	Attended	LAeq (15 min)	56.2	51	JH Works Compliant	Dominant noise source was traffic from local roads. Works were inaudible. JHG works compliant.
33 Isabel Street, Cecil Hills	06/12/2025	Night	NCA_16b	Attended	LAeq (15 min)	49.1	79	JH Works Compliant	Dominant noise source was project works. Works were compliant with the PNL. JHG works compliant.
33 Isabel Street, Cecil Hills	06/12/2025	Night	NCA_16b	Attended	LAeq (15 min)	48.2	79	JH Works Compliant	Dominant noise source was project works. Works were compliant with the PNL. JHG works compliant.
3 Meredith Way, Cecil Hills	06/12/2025	Night	NCA_16b	Attended	LAeq (15 min)	43.8	69	JH Works Compliant	Dominant noise source was traffic from local roads. Works were inaudible. JHG works compliant.

Location Description	Monitoring date	Monitoring period	NCA	Attended or Continuous	Parameter	Measured value dB(A)	Goals and targets dB(A)	Project OOHW Compliance	Comments/Field Observations
33 Isabel Street, Cecil Hills	06/12/2025	Night	NCA_16b	Attended	LAeq (15 min)	47.5	79	JH Works Compliant	Dominant noise source was project works. Works were compliant with the PNL. JHG works compliant.
2055- 2059 Elizabeth Drive, Cecil Park	07/12/2025	Night	NCA_35	Attended	LAeq (15 min)	52.3	51	JH Works Compliant	Dominant noise source was traffic from local roads. Works were inaudible. JHG works compliant.
18 Cecil Road, Cecil Park	07/12/2025	Night	NCA_35	Attended	LAeq (15 min)	50.2	65	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
37-73 Wallgrove Road, Cecil Park	07/12/2025	Night	NCA_17	Attended	LAeq (15 min)	49.4	67	JH Works Compliant	Dominant noise source was project works. Works were compliant with the PNL. JHG works compliant.
37-73 Wallgrove Road, Cecil Park	07/12/2025	Night	NCA_17	Attended	LAeq (15 min)	50.4	67	JH Works Compliant	Dominant noise source was traffic from local roads. Works were inaudible. JHG works compliant.
2055- 2059 Elizabeth Drive, Cecil Park	07/12/2025	Night	NCA_35	Attended	LAeq (15 min)	59.3	51	JH Works Compliant	Dominant noise source was traffic from local roads. Works were inaudible. JHG works compliant.
33 Isabel Street, Cecil Hills	07/12/2025	Night	NCA_16b	Attended	LAeq (15 min)	47.3	79	JH Works Compliant	Dominant noise source was project works. Works were compliant with the PNL. JHG works compliant.
86 Station Street, Rooty Hill	08/12/2025	Night	NCA_26	Attended	LAeq (15 min)	56.7	65	JH Works Compliant	Dominant noise source was project works. Works were compliant with the PNL. JHG works compliant.
27 Myra Street, Plumpton	08/12/2025	Night	NCA_31	Attended	LAeq (15 min)	54.8	71	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
5 Nimbin Avenue, Hoxton Park	08/12/2025	Night	NCA_08	Attended	LAeq (15 min)	47.6	51	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
15 Lambert Street, Plumpton	08/12/2025	Night	NCA_31	Attended	LAeq (15 min)	55.6	72	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
144 Rooty Hill Road, Eastern Creek	09/12/2025	Night	NCA_23	Attended	LAeq (15 min)	57.1	52	JH Works Compliant	Dominant noise source was traffic from local roads. Works were inaudible. JHG works compliant.
489-499 Wallgrove Rd, Horsley Park	09/12/2025	Night	NCA_20	Attended	LAeq (15 min)	66.2	70	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.

Location Description	Monitoring date	Monitoring period	NCA	Attended or Continuous	Parameter	Measured value dB(A)	Goals and targets dB(A)	Project OOHW Compliance	Comments/Field Observations
289-293 Chandos Road, Horsley Park	09/12/2025	Night	NCA_21	Attended	LAeq (15 min)	55.8	55	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
185 Middleton Drive, Middleton Grange	09/12/2025	Night	NCA_10	Attended	LAeq (15 min)	48.9	59	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
31 Pegasus Avenue, Hinchinbrook	10/12/2025	Night	NCA_09	Attended	LAeq (15 min)	49.3	51	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
86 Station Street, Rooty Hill	10/12/2025	Night	NCA_26	Attended	LAeq (15 min)	55.6	65	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
31 Pegasus Avenue, Hinchinbrook	10/12/2025	Night	NCA_26	Attended	LAeq (15 min)	52.6	48	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
5 Nimbin Avenue, Hoxton Park	10/12/2025	Night	NCA_26	Attended	LAeq (15 min)	48.1	53	JH Works Compliant	Dominant noise source was background noise including traffic, insects and airplanes. Works were compliant with the PNL. JHG works compliant.
146 Eskdale Street, Minchinbury	11/12/2025	Night	NCA_26	Attended	LAeq (15 min)	51.4	47	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
33 Isabel Street, Cecil Hills	12/12/2025	Night	NCA_16b	Attended	LAeq (15 min)	50.5	79	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
18 Cecil Road, Cecil Park	12/12/2025	Night	NCA_35	Attended	LAeq (15 min)	60.1	65	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
2055-2059 Elizabeth Drive, Cecil Park	12/12/2025	Night	NCA_17	Attended	LAeq (15 min)	60.4	67	JH Works Compliant	Dominant noise source was traffic from local roads. Works were inaudible. JHG works compliant.
37-73 Wallgrove Road, Cecil Park	12/12/2025	Night	NCA_35	Attended	LAeq (15 min)	54.3	51	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
33 Isabel Street, Cecil Hills	12/12/2025	Night	NCA_16b	Attended	LAeq (15 min)	50.2	79	JH Works Compliant	Dominant noise source was project works. Works were compliant with the PNL. JHG works compliant.
33 Isabel Street, Cecil Hills	12/12/2025	Night	NCA_16b	Attended	LAeq (15 min)	57.4	75	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.

Location Description	Monitoring date	Monitoring period	NCA	Attended or Continuous	Parameter	Measured value dB(A)	Goals and targets dB(A)	Project OOHW Compliance	Comments/Field Observations
18 Cecil Road, Cecil Park	12/12/2025	Night	NCA_35	Attended	LAeq (15 min)	63.3	75	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
5 Nimbin Avenue, Hoxton Park	14/12/2025	Night	NCA_08	Attended	LAeq (15 min)	52.8	53	JH Works Compliant	Dominant noise source was traffic from local roads and high winds. Works were inaudible. JHG works compliant.
31 Pegasus Avenue, Hinchinbrook	14/12/2025	Night	NCA_09	Attended	LAeq (15 min)	51.9	51	JH Works Compliant	Dominant noise source was traffic from local roads and high winds. Works were inaudible. JHG works compliant.
3A Gregory Street, Glendenning	14/12/2025	Night	NCA_31	Attended	LAeq (15 min)	44.8	65	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
12 Sperring Avenue, Oakhurst	15/12/2025	Night	NCA_31	Attended	LAeq (15 min)	50.6	73	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
5 Nimbin Avenue, Hoxton Park	15/12/2025	Night	NCA_08	Attended	LAeq (15 min)	45.1	51	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
31 Pegasus Avenue, Hinchinbrook	15/12/2025	Night	NCA_09	Attended	LAeq (15 min)	52	51	JH Works Compliant	Dominant noise source was traffic from local roads. Works were inaudible. JHG works compliant.
27 Myra Street, Plumpton	17/12/2025	Night	NCA_31	Attended	LAeq (15 min)	47.9	76	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
64 Woodley Cres, Glendenning	17/12/2025	Night	NCA_31	Attended	LAeq (15 min)	42.4	63	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
5 Nimbin Avenue, Hoxton Park	17/12/2025	Night	NCA_08	Attended	LAeq (15 min)	48.3	53	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
27 Myra Street, Plumpton	18/12/2025	Night	NCA_31	Attended	LAeq (15 min)	49.6	76	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
64 Woodley Cres, Glendenning	18/12/2025	Night	NCA_31	Attended	LAeq (15 min)	44	63	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.
27 Myra Street, Plumpton	19/12/2025	Night	NCA_31	Attended	LAeq (15 min)	52	76	JH Works Compliant	Dominant noise source was traffic from local roads. Works were compliant with the PNL. JHG works compliant.

Note:

1. LAeq (15min) - The A-weighted equivalent continuous (energy average) A-weighted sound pressure level over a 15-minute period.
2. dBA - Decibels using the A-weighted scale measured according to the frequency of the human ear.

3.2 Vibration monitoring

Vibration monitoring was undertaken during the reporting period in accordance with the requirements of the M7M12 Construction Noise and Vibration Monitoring Program (M712UDC-JHGRP-M7A-EN-PLN-000074).

All works were deemed compliant as they complied with applicable criteria and are detailed in Table 3-2.

Table 3-2 Vibration monitoring data

Monitoring Location	Monitoring Date	Attended or Continuous Monitoring	Measured VDV (m/s ^{1.75})	VDV Target (m/s ^{1.75})	VDV Compliant	Measured PPV (mm/s)	PPV Target (mm/s)	PPV Compliant	Comments/ Field Observations
24 Haleluka Crescent, Plumpton	02/12/2025	Attended	0.07	0.4	Compliant	0.11	25	Compliant	Works were monitored and found to be compliant with the associated criteria
44 Woodley Cres, Glendenning	03/12/2025	Attended	0.06	0.4	Compliant	0.09	25	Compliant	Works were monitored and found to be compliant with the associated criteria
11 Gilpin Place, Plumpton	03/12/2025	Attended	0.07	0.4	Compliant	0.11	25	Compliant	Works were monitored and found to be compliant with the associated criteria
44 Woodley Cres, Glendenning	04/12/2025	Attended	0.10	0.4	Compliant	0.15	25	Compliant	Works were monitored and found to be compliant with the associated criteria
15 Lambert Avenue, Plumpton	05/12/2025	Attended	0.08	0.4	Compliant	0.12	25	Compliant	Works were monitored and found to be compliant with the associated criteria
15 Lambert Street, Plumpton	08/12/2025	Attended	0.20	0.4	Compliant	0.17	25	Compliant	Works were monitored and found to be compliant with the associated criteria
11 Gilpin Place, Plumpton	09/12/2025	Attended	0.11	0.4	Compliant	0.3	25	Compliant	Works were monitored and found to be compliant with the associated criteria
15 Lambert Avenue, Plumpton	09/12/2025	Attended	0.07	0.4	Compliant	0.11	25	Compliant	Works were monitored and found to be compliant with the associated criteria

33 Isabel Street, Cecil Hills	12/12/2025	Attended	0.07	0.4	Compliant	0.11	25	Compliant	Works were monitored and found to be compliant with the associated criteria
44 Woodley Crescent, Glendenning	14/12/2025	Attended	0.06	0.4	Compliant	0.09	25	Compliant	Works were monitored and found to be compliant with the associated criteria
50 Polonia Avenue, Plumpton	15/12/2025	Attended	0.07	0.4	Compliant	0.10	25	Compliant	Works were monitored and found to be compliant with the associated criteria
11 Gilpin Place, Plumpton	16/12/2025	Attended	0.07	0.4	Compliant	0.11	25	Compliant	Works were monitored and found to be compliant with the associated criteria
24 Haleluka Crescent, Plumpton	16/12/2025	Attended	0.07	0.4	Compliant	0.11	25	Compliant	Works were monitored and found to be compliant with the associated criteria
50 Polonia Avenue, Plumpton	16/12/2025	Attended	0.06	0.4	Compliant	0.09	25	Compliant	Works were monitored and found to be compliant with the associated criteria
11 Gilpin Place, Plumpton	16/12/2025	Attended	0.07	0.4	Compliant	0.10	25	Compliant	Works were monitored and found to be compliant with the associated criteria
24 Haleluka Crescent, Plumpton	17/12/2025	Attended	0.07	0.4	Compliant	0.10	25	Compliant	Works were monitored and found to be compliant with the associated criteria
15 Lambert Avenue, Plumpton	17/12/2025	Attended	0.07	0.4	Compliant	0.11	25	Compliant	Works were monitored and found to be compliant with the associated criteria
28 Myra Street, Plumpton	17/12/2025	Attended	0.08	0.4	Compliant	0.13	25	Compliant	Works were monitored and found

									to be compliant with the associated criteria
44 Woodley Crescent, Glendenning	17/12/2025	Attended	0.07	0.4	Compliant	0.10	25	Compliant	Works were monitored and found to be compliant with the associated criteria
15 Lambert Avenue, Plumpton	19/12/2025	Attended	0.08	0.4	Compliant	0.12	25	Compliant	Works were monitored and found to be compliant with the associated criteria
28 Myra Street, Plumpton	19/12/2025	Attended	0.08	0.4	Compliant	0.12	25	Compliant	Works were monitored and found to be compliant with the associated criteria

Note:

1. VDV – Vibration Dose Value
2. PPV – Peak Particle Velocity

4 Discharge Water Quality Monitoring

Offsite discharge occurred during December 2025 from sediment basins across the Project.

All discharges were compliant with the requirements of the Project EPL (#21829) and are outlined in Table 4-1.

Table 4-1 Sediment basin discharge monitoring data for December 2025

Location	Date	Analyte	Units	Limit	Result	Comments
SB06	02/12/2025	pH	pH	6.5-8.5	7.92	Compliant with discharge criteria.
		Turbidity	NTU	50	16.9	
		Oil and grease	Visible	Not visible	Not visible	
SB07	02/12/2025	pH	pH	6.5-8.5	8.16	Compliant with discharge criteria.
		Turbidity	NTU	50	43.9	
		Oil and grease	Visible	Not visible	Not visible	
SB16	02/12/2025	pH	pH	6.5-8.5	7.95	Compliant with discharge criteria.
		Turbidity	NTU	50	40.5	
		Oil and grease	Visible	Not visible	Not visible	
SB08	10/12/2025	pH	pH	6.5-8.5	8.25	Compliant with discharge criteria.
		Turbidity	NTU	50	29	
		Oil and grease	Visible	Not visible	Not visible	
SB16	17/12/2025	pH	pH	6.5-8.5	8.13	Compliant with discharge criteria.
		Turbidity	NTU	50	42.1	
		Oil and grease	Visible	Not visible	Not visible	
SB02	17/12/2025	pH	pH	6.5-8.5	8	Compliant with discharge criteria.
		Turbidity	NTU	50	30.7	
		Oil and grease	Visible	Not visible	Not visible	
SB13	17/12/2025	pH	pH	6.5-8.5	7.52	Compliant with discharge criteria.
		Turbidity	NTU	50	24.4	
		Oil and grease	Visible	Not visible	Not visible	
SB06	17/12/2025	pH	pH	6.5-8.5	8.18	Compliant with discharge criteria.
		Turbidity	NTU	50	14.2	

		Oil and grease	Visible	Not visible	Not visible	
--	--	----------------	---------	-------------	--------------------	--